

# Certificate



SIL/PL  
Capability

www.tuv.com  
ID 0600000000

**No.: 968/FSP 3037.00/26**

|                                                            |                                                                                                                                                                                                                                                                                                                                                                                      |                             |                                                                         |
|------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------|-------------------------------------------------------------------------|
| <b>Product tested</b>                                      | Rotary hydraulic actuators<br>Rotary pneumatic actuators                                                                                                                                                                                                                                                                                                                             | <b>Certificate holder</b>   | Duxvalves B.V.<br>Bornsestraat 321<br>7601 PB Almelo<br>The Netherlands |
| <b>Type designation</b>                                    | Duxdrive DDH & DDP<br>Series SRC / SRO<br>Details see Revision List                                                                                                                                                                                                                                                                                                                  |                             |                                                                         |
| <b>Codes and standards</b>                                 | IEC 61508 parts 1-2:2010                                                                                                                                                                                                                                                                                                                                                             | EN 17955:2024 (non accred.) |                                                                         |
| <b>Intended application</b>                                | Safety function: On loss of hydraulic or pneumatic pressure supply, move into fail safe position by spring force (NC/NO)<br><br>The actuators are suitable for use in a safety instrumented system up to SIL 2 (low demand mode). Under consideration of the minimum required hardware fault tolerance HFT = 1 for the complete final element the actuators may be used up to SIL 3. |                             |                                                                         |
| <b>Specific requirements</b>                               | The instructions of the associated Installation, Operating and Safety Manual shall be considered.                                                                                                                                                                                                                                                                                    |                             |                                                                         |
| Summary of test results see back side of this certificate. |                                                                                                                                                                                                                                                                                                                                                                                      |                             |                                                                         |

The issue of this certificate is based upon an evaluation in accordance with the Certification Program CERT FSP1 V3.0:2020 in its actual version, whose results are documented in Report No. 968/FSP 3037.00/26 dated 2026-03-26. This certificate is valid only for products, which are identical with the product tested. Issued by the certification body accredited by DAkkS according to DIN EN ISO/IEC 17065. The accreditation is only valid for the scope listed in the annex to the accreditation certificate D-ZE-11052-02-00.

**TÜV Rheinland Industrie Service GmbH**  
Bereich Automation  
Funktionale Sicherheit  
Am Grauen Stein, 51105 Köln

Köln, 2026-04-16

Certification Body Safety & Security for Automation & Grid

Dipl.-Ing. (FH) Wolf Rückwart

**Holder:** Duxvalves B.V.  
 Bornsestraat 321  
 7601 PB Almelo  
 The Netherlands

**Product tested:** Rotary hydraulic actuators  
 Rotary pneumatic actuators  
 Type: Duxdrive DDH & DDP  
 Details see Revision List

### Results of Assessment

|                          |                               |
|--------------------------|-------------------------------|
| Route of Assessment      | $2_H / 1_S$                   |
| Type of Sub-system       | Type A                        |
| Mode of Operation        | Low Demand Mode               |
| Utilization Rate         | Low and High Utilization Rate |
| Hardware Fault Tolerance | HFT = 0                       |
| Systematic Capability    | <b>SC 3</b>                   |

### Move into fail safe position by spring force (NC/NO)

|                                               |                  |               |               |
|-----------------------------------------------|------------------|---------------|---------------|
| Dangerous Failure Rate                        | $\lambda_D$      | 3.80 E-08 / h | <b>38 FIT</b> |
| Average Probability of Failure on Demand 1oo1 | $PFD_{avg}(T_1)$ | 1.69 E-04     |               |
| Average Probability of Failure on Demand 1oo2 | $PFD_{avg}(T_1)$ | 1.69 E-05     |               |

Assumptions for the calculations above: DC = 0 %,  $T_1$  = 1 year, MRT = 72 h,  $\beta_{1oo2}$  = 10 %

### Origin of failure rates

The stated failure rates are the result of an FMEDA acc. EN 17955, Annex C.

The stated failure rates do not release the end-user from collecting and evaluating application-specific reliability data.

### Periodic Tests and Maintenance

The given values require periodic tests and maintenance as described in the Safety Manual.

The operator is responsible for the consideration of specific external conditions (e.g. ensuring of required quality of media, max. temperature, time of impact), and adequate test cycles.